



- [Close Window](#)
- [Print This Page](#)
- [Expand All](#) | [Collapse All](#)

EQ-0000066

Equipment Comparison

Existing Description	High Bay	Proposed Description	LED
Existing Area Description	Manufacturing Floor and Warehouse	Proposed Count	700
Existing Count	700	Proposed Make	Vigilent
Existing Lamp Wattage	900	Proposed Model	High Output
Existing Lamp Lumen	30,000	Proposed Lamp Wattage	484
Existing Controls?	☐	Proposed Lamp Lumen	69,100
Existing Annual Operating Hours/Unit	8,688	Proposed Controls?	☒
Existing Annual Energy Usage/Unit	5,473,440	Proposed DLC/ENERGY STAR Designations	TBD
		Proposed Annual Operating Hours/Unit	8,688

System Information

Created By	Stewart Austin, 12/29/2025, 2:20 PM	Last Modified By	Stewart Austin, 12/29/2025, 2:20 PM
Record Type	Lighting	Funding Request	855400LLC
Equipment Number	EQ-0000066	Funding Request Supplement	FR-02197 - CITCO High-Efficiency Electric P/M/C/L Sub-Application

Copyright © 2000-2025 salesforce.com, inc. All rights reserved.