



- [Close Window](#)
- [Print This Page](#)
- [Expand All](#) | [Collapse All](#)

EQ-0000067

Equipment Comparison

Existing Description	Incandescent and Fluorescent	Proposed Description	LED
Existing Area Description	Office	Proposed Count	344
Existing Count	344	Proposed Make	Phillips
Existing Lamp Wattage	125	Proposed Model	Day - Brite
Existing Lamp Lumen	3,000	Proposed Lamp Wattage	50
Existing Controls?	☐	Proposed Lamp Lumen	3,605
Existing Annual Operating Hours/Unit	8,688	Proposed Controls?	☒
Existing Annual Energy Usage/Unit	373,584	Proposed DLC/ENERGY STAR Designations	TBD
		Proposed Annual Operating Hours/Unit	8,688

System Information

Created By	Stewart Austin, 12/29/2025, 2:24 PM	Last Modified By	Stewart Austin, 12/29/2025, 2:30 PM
Record Type	Lighting	Funding Request	855400LLC
Equipment Number	EQ-0000067	Funding Request Supplement	FR-02197 - CITCO High-Efficiency Electric P/M/C/L Sub-Application

Copyright © 2000-2025 salesforce.com, inc. All rights reserved.